



# WIŚNIEWSKI

## Manufacturer's declaration

Declaration no.: 1281/2020

**I hereby declare with full responsibility that the product conforms to the technical specification indicated in section 5, on condition that it has been installed in accordance with its Installation and Operating Manual.**

1. Product manufacturer: **WIŚNIEWSKI Sp. z o.o. S.K.A.  
PL 33-311 Wielogłowy 153,**
2. Product name: **Industrial sectional doors with MAKROPRO 2.0. type drive**
3. Intended use and scope of application: **The door is intended as a vertical barrier in industrial, commercial, public utility and garage buildings. The intended use requires providing safe indoor access to pedestrians, handled goods and vehicles and their drivers.**
4. Declared product performance: **Noise permeating a room during the "opening-closing" cycle:**

MAKROPRO 2.0 with GFA type SE9 drive	<b>A L<sub>Aeq</sub> = 36 [dB];</b>
MAKROPRO 2.0 with GFA type SE9 drive and vibroacoustic separators	<b>A L<sub>Aeq</sub> = 33 [dB];</b>
MAKROPRO 2.0 with GFA type S8.60FU drive	<b>A L<sub>Aeq</sub> = 24 [dB];</b>
MAKROPRO 2.0 with GFA type SE8.60FU drive and vibroacoustic separators	<b>A L<sub>Aeq</sub> = 21 [dB],</b>

5. Technical specification: **PN – 87/B-02156 "Akustyka budowlana – Metody pomiaru poziomu dźwięku A w budynkach" (Construction acoustics – A-level sound measurement methods in buildings)**  
**Ordinance of the Minister of Infrastructure of 12 April 2002 on technical conditions to be met by buildings and their locations (Journal of Laws no. 75, item 690, of 15 June 2002)**

**Name of the accredited certification body:**

**Instytut Techniki Budowlanej (Building Research Institute)  
in Warsaw,**

**Notified body identification number: 1488**



WIŚNIEWSKI Sp. z o.o. S.K.A.

mgr inż. Dariusz Złocki  
Dyrektor Biura Konstrukcyjnego

.....  
(full name and signature of authorised person)

Wielogłowy, date: 20.10.2020